




Air Conditioning & Heating

CPG COMMERCIAL

15- & 20-Ton, THREE-PHASE PACKAGED GAS/ELECTRIC UNITS



15 Tons

COOLING CAPACITY: 180,000 BTU/H

HEATING CAPACITY: 350,000 BTU/H

20 Tons

COOLING CAPACITY: 240,000 BTU/H

HEATING CAPACITY: 400,000 BTU/H

Contents

Nomenclature	2
Product Features	3
Product Specifications	4
Airflow Data.....	6
Expanded Cooling Data.....	8
Dimensions.....	12
Wiring Diagrams	16
Accessories.....	20



* Complete warranty details available from your local dealer or at www.goodmanmfg.com.



NOMENCLATURE

	C	P	G	240	210	3	B	X	X	X
	1	2	3	4,5,6	7,8,9	10	11	12	13	14
Brand										
C Commercial										
Configuration										
P Packaged Unit										
Application										
C Cooling										
G Gas Heat										
H Heat Pump										
Nominal Gross Cooling Capacity										
036 3 Tons 102 8½ Tons										
048 4 Tons 120 10 Tons										
060 5 Tons 150 12½ tons										
072 6 Tons 180 15 Tons										
090 7½ Tons 240 20 Tons										
Nominal Heating Capacity										
CPG										
045 45,000 BTU/h										
090 90,000 BTU/h										
115 115,000 BTU/h										
140 140,000 BTU/h										
210 210,000 BTU/h										
350 350,000 BTU/h										
400 400,000 BTU/h										
CPC/CPH (Factory-Installed Electric Heat)										
XXX No Heat										
010 10 kW										
015 15 kW										
016 15 kW										
018 18 kW										
020 20 kW										
025 25 kW										
030 30 kW										
031 30 kW										
045 45 kW										
046 45 kW										
060 60 kW										
075 75 kW										
Voltage										
1 208V 1-Phase										
2 220/240V 1-Phase 50 Hz										
3 208/230V 3-Phase										
4 460V 3-Phase										
5 380/415V 3-Phase 50 Hz										
7 575V 3-Phase										
Factory-Installed Options										
X No Options										
A Non-powered convenience outlet										
B Powered convenience outlet										
C Low-ambient kit										
F Non-powered convenience outlet; Low-ambient kit										
M Powered convenience outlet; Low-ambient kit										
Factory-Installed Options										
X Standard Aluminized Heat Exchanger										
A Condenser Coil Hail Guard										
B Condenser Coil Hail Guard Treated Condenser Coil (UltraGold)										
C Condenser Coil Hail Guard Stainless Steel Heat Exchanger										
D Condenser Coil Hail Guard Treated Condenser Coil (UltraGold) Stainless-Steel Heat Exchanger										
J Treated Condenser Coil (UltraGold)										
S Stainless-Steel Heat Exchanger										
T Treated Condenser Coil (UltraGold) Stainless-Steel Heat Exchanger										
Factory-Installed Options										
X No Options										
A Downflow Economizer										
Supply Fan/Drive Type/Motors										
B Belt Drive										
D Direct Drive										
H High-Static Belt Drive (Factory-Installed)										
Factory-Installed Options										
• Condenser Hail Guards: Louvered metal guards help protect the condenser coil from damage from hail and debris. Available as a factory-installed option on 3- to 12½-ton units. Hail guards are standard on 15- and 20-ton units.										
• Stainless-Steel Heat Exchanger (CPG units only): A tubular heat exchanger made of 409-type stainless steel is installed in the unit.										
• Ultra-Gold Condenser Coil: Offers increased corrosion resistance of the condenser coil.										
• Low-Ambient Kit: Allows for cooling operation at lower outdoor temperatures. On the 3- to 6-ton units, cooling operation is extended from 60°F ambient temperature to 35°F outside air temperature. On 7½- to 20-ton units, cooling operation is extended from 35°F ambient temperature to 0°F outside air temperature.										
• Economizers (Downflow): Based on air conditions, can provide outside air to cool the space.										
• High Static Kits: Provides airflow in higher static applications.										
• Electric Heat Kits (CPC and CPH units only): Available in all voltage options.										
• Non-powered Convenience Outlet: A 120V, 15A, GFCI outlet makes it easier for technicians to service the unit once an electrician runs power to the outlet.										
• Powered Convenience Outlet: A 120V, 15A, GFCI outlet powered with a transformer built into the unit.										

PRODUCT FEATURES

Standard Features

- R-410A chlorine-free refrigerant
- TuffTube™ tubular heat exchanger
- High-efficiency scroll compressor
- Copper tube / aluminum fin coils
- High- and low-pressure switches
- High-capacity, steel-cased filter dryer
- Built-in filter rack with standard 2" filters (convertible to 4" filters)
- 24-volt terminal strip
- Contactor with lugs
- Easy to service
- Bottom utility entry
- Complies with California NOx emissions standards
- AHRI Certified; ETL Listed

Cabinet Features

- Heavy-gauge, galvanized-steel cabinet with UV-resistant powder-paint finish
- Full Perimeter Rail
- Sloped drain pan

PRODUCT SPECIFICATIONS — 15 Tons

	CPG180350 3B***	CPG180350 4B***	CPG180*** 7B***
COOLING CAPACITY			
Total, BTU/h	180,000	180,000	180,000
Sensible BTU/h	127,500	127,500	127,500
EER / IEER	10.8 / 11	10.8 / 11	10.8 / 11
Decibels	88	88	88
ARI Reference #s	3965698	3965698	3965698
HEATING CAPACITY			
Max. Input: High / Low KBTU/h	350 / 262	350 / 262	350 / 262
Output: High / Low KBTU/h	280 / 210	280 / 210	280 / 210
Steady State Efficiency (%)	80	80	80
Temperature Rise: High / Low (°F)	30-60 / 20-50	30-60 / 20-50	30-60 / 20-50
No. of Burners	7	7	7
EVAPORATOR MOTOR / COIL			
Motor Type (Belt Drive)	Std Static	Std Static	Std Static
Indoor Nominal CFM	5,400	5,400	5,400
Indoor Motor FLA (Cooling)	12.7	6.4	5.1
Horsepower - RPM	5.0 - 1,725	5.0 - 1,725	5.0 - 1,725
Metering Device	TXV	TXV	TXV
Filter Size (#)	20 x 25 x 2 (6)	20 x 25 x 2 (6)	20 x 25 x 2 (6)
Drain Size (NPT)	1"	1"	1"
R-410A Refrigerant Charge Cir #1 & 2	290 oz.	290 oz.	290 oz.
Evaporator Coil Face Area (ft²)	20	20	20
Rows Deep / Fins per Inch	4 / 16	4 / 16	4 / 16
BELT DRIVE EVAP FAN DATA			
# of Wheels (D x W)	2 (15" x 12")	2 (15" x 12")	2 (15" x 12")
Motor Sheave	1VP50 x 1½"	1VP50 x 1½"	1VP50 x 1½"
Blower Sheave / Belt	BK90 x 1¾" / BX42	BK90 x 1¾" / BX42	BK90 x 1¾" / BX42
CONDENSER FAN / COIL			
Quantity of Condenser Fan Motors	3	3	3
Horsepower - RPM	⅓ - 1,075	⅓ - 1,075	⅓ - 1,075
Fan Diameter / # Fan Blades	22 / 3	22 / 3	22 / 3
Outdoor Nominal CFM	7,200	7,200	7,200
Face Area (ft²)	53.3	53.3	53.3
Rows Deep / Fins per Inch	2 / 18	2 / 18	2 / 18
COMPRESSOR			
Quantity / Type	2 / Scroll	2 / Scroll	2 / Scroll
Compressor RLA / LRA CIR. #1	25 / 164	12.2 / 100	9.0 / 78
Compressor RLA / LRA CIR. #2	29.5 / 195	14.7 / 95	12.2 / 80
ELECTRICAL DATA / STATIC			
Voltage / Phase / Frequency	208-230/3/60	460/3/60	575/3/60
Standard Max Static	1.2	1.2	1.2
Outdoor Fan FLA / LRA	2.4 / 5.2	1.2 / 2.6	.9 / 2.2
Total Unit Amps	74.4	36.9	29
Min. Circuit Ampacity¹	81.8	40.6	32.1
Max. Overcurrent Protection (amps)²	100	50	40
Entrance Power Supply	2½"	2½"	2½"
Entrance Control Voltage	⅞"	⅞"	⅞"
OPERATING WEIGHT (LBS)			
SHIP WEIGHT (LBS)			
	2155	2155	2155
	2270	2270	2270

¹ Wire size should be determined in accordance with National Electrical Codes. Extensive wire runs will require larger wire sizes.

² May use fuses or HACR-type circuit breakers of the same size as noted.

Note: Always check the S&R plate for electrical data on the unit being installed.

PRODUCT SPECIFICATIONS — 20 Tons

	CPG240 4003B***	CPG240 4004B***	CPG240 4007B***
COOLING CAPACITY			
Total, BTU/h	240,000	240,000	240,000
Sensible BTU/h	170,000	170,000	170,000
EER / IEER	9.8 / 10.0	9.8 / 10.0	9.8 / 10.0
Decibels	88.3	88.3	88.3
AHRI Reference #s	3897346	3897346	3897346
HEATING CAPACITY			
Max. Input High / Low (KBTU/h)	400 / 300	400 / 300	400 / 300
Output BTU/h	320 / 240	320 / 240	320 / 240
Steady State Efficiency (%)	80	80	80
Temperature Rise Range (°F) High/Low	25-55 / 15-45	25-55 / 15-45	25-55 / 15-45
No. of Burners	8	8	8
EVAPORATOR MOTOR / COIL			
Motor Type (Belt Drive)	Std Static Belt Drive	Std Static Belt Drive	Std Static Belt Drive
Indoor Nominal CFM	7,000	7,000	7,000
Indoor Motor FLA (Cooling)	12.7	6.4	5.1
Horsepower - RPM	5.0 - 1,725	5.0 - 1,725	5.0 - 1,725
Metering Device	TXV	TXV	TXV
Filter Size (#)	25 x 25 x 2 (6)	25 x 25 x 2 (6)	25 x 25 x 2 (6)
Drain Size (NPT)	1"	1"	1"
R-410A Refrigerant Charge Cir #s 1 & 2	320 oz.	320 oz.	320 oz.
Evaporator Coil Face Area (ft²)	20	20	20
Rows Deep / Fins per Inch	4 / 16	4 / 16	4 / 16
BELT DRIVE EVAP FAN DATA			
# of Wheels (D x W)	2 (15" x 15")	2 (15" x 15")	2 (15" x 15")
Motor Sheave	1VP60 x 1⅝"	1VP60 x 1⅝"	1VP60 x 1⅝"
Blower Sheave / Belt	BK100 x 17/16" / BX46	BK100 x 17/16" / BX46	BK100 x 17/16" / BX46
CONDENSER FAN / COIL			
Quantity of Condenser Fan Motors	3	3	3
Horsepower - RPM	⅓ - 1,075	⅓ - 1,075	⅓ - 1,075
Fan Diameter / # Fan Blades	22 / 3	22 / 3	22 / 3
Outdoor Nominal CFM	7,200	7,200	7,200
Face Area (ft²)	53.3	53.3	53.3
Rows Deep / Fins per Inch	2 / 18	2 / 18	2 / 18
COMPRESSOR			
Quantity / Type	2 / Scroll	2 / Scroll	2 / Scroll
Compressor RLA / LRA ea.	33.3 / 239	17.9 / 125	12.8 / 80
ELECTRICAL DATA / STATIC			
Voltage / Phase / Frequency	208-230/3/60	460/3/60	575/3/60
Standard Max Static	1.4	1.4	1.4
Outdoor Fan FLA / LRA	2.4 / 5.2	1.2 / 2.6	.9 / 2.2
Total Unit Amps	86.5	45.8	33.4
Min. Circuit Ampacity¹	95	50	37
Max. Overcurrent Protection (amps)²	125	60	45
Entrance Power Supply	2⅝"	2⅝"	2⅝"
Entrance Control Voltage	⅝"	⅝"	⅝"
OPERATING WEIGHT (LBS)	2275	2275	2275
SHIP WEIGHT (LBS)	2390	2390	2390

¹ Wire size should be determined in accordance with National Electrical Codes. Extensive wire runs will require larger wire sizes.

² May use fuses or HACR-type circuit breakers of the same size as noted.

Note: Always check the S&R plate for electrical data on the unit being installed.

AIRFLOW DATA — 15 Tons

STANDARD BELT DRIVE — DOWN SHOT

ESP (" H ₂ O)	TURNS OPEN													
	0		1		2		3		4		5		6	
	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP
0.2							0.00	6827	2.67	6394	2.28	5982	1.94	
0.4					7079	3.20	6623	2.76	6161	2.34	5706	1.98	5271	1.66
0.6			6903	3.32	6405	2.83	5923	2.41	5434	2.02	4949	1.68		
0.8	6717	3.42	6198	2.92	5668	2.45	5152	2.05						
1.0	5975	2.99	5418	2.51										
1.2	5147	2.55												

HIGH-STATIC BELT DRIVE — DOWN SHOT

ESP (" H ₂ O)	TURNS OPEN													
	0		1		2		3		4		5		6	
	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP
1.0									6690	3.69	6008	3.02	5321	2.43
1.2							6653	3.95	5922	3.22	5182	2.58		
1.4					6634	2.80	5857	3.44	5056	2.74				
1.6			6638	4.55	5808	2.43	4948	2.91						
1.8	6683	4.93	5784	3.95	4855	2.05								
2.0	5803	4.27	4788	3.32										

NOTES

- Airflow table represent dry coil with filters installed; SCFM correction factor for wet coil is 4%.
- Any adjustment made to the blower should not cause the motor to draw more than the motor rated RLA. Application that exceed the above could require a larger motor. Minimum rated SCFM is 350 per ton.
- High-static airflow requires installation of high kit (HSKT180G) or factory-built high-static model.
- Unit factory shipped with the sheave set at 2.5 turns open.

AIRFLOW DATA — 20 Tons

STANDARD BELT DRIVE — DOWN SHOT

ESP (" H ₂ O)	TURNS OPEN													
	0		1		2		3		4		5		6	
	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP
0.2					9359	4.92	8991	3.79	8621	3.54	8188	3.27	7826	3.04
0.4			9018	3.18	8632	4.39	8251	3.39	7867	3.15	7363	2.85	6992	2.63
0.6			8279	2.96	7879	3.86	7484	2.99	7085	2.75				
0.8	7957	4.82	7513	2.73	7097	3.35								
1.0	7179	4.23	6716	2.49										
1.2	6368	3.66												

HIGH-STATIC BELT DRIVE — DOWN SHOT

ESP (" H ₂ O)	TURNS OPEN													
	0		1		2		3		4		5		6	
	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP
1.0							9001	6.83	8394	6.01	7797	4.78	7227	4.28
1.2					8891	6.83	8262	6.15	7632	5.35	7012	4.20		
1.4			8811	6.86	8148	6.15	7495	5.48	6841	4.71				
1.6			8065	6.19	7377	5.48								
1.8	7998	6.89	7290	5.52										
2.0	7221	6.10												

NOTES

- Airflow table represent dry coil with filters installed; SCFM correction factor for wet coil is 4%.
- Any adjustment made to the blower should not cause the motor to draw more than the motor rated RLA. Application that exceed the above could require a larger motor. Minimum rated SCFM is 350 per ton.
- High-static airflow requires installation of high kit (HSKT240) or factory-built high-static model.
- Unit factory shipped with the sheave set at 2.5 turns open.

EXPANDED COOLING DATA — 15 TONS

		OUTDOOR AMBIENT TEMPERATURE																																			
		65						75						85						95						105						115					
		ENTERING INDOOR WET BULB TEMPERATURE																																			
IDB	AIRFLOW	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71												
70	6075	MBh	176.4	182.8	200.3	-	172.3	178.6	195.6	-	168.2	174.3	191.0	-	164.1	170.1	186.3	-	155.9	161.6	177.0	-	144.4	149.7	164.0	-											
		S/T	0.71	0.59	0.41	-	0.74	0.62	0.43	-	0.76	0.63	0.44	-	0.78	0.65	0.45	-	0.81	0.68	0.47	-	0.82	0.68	0.47	-											
		ΔT	19	16	12	-	19	17	13	-	19	17	13	-	19	17	13	-	19	17	13	-	18	15	12	-											
		HI PR	234	252	266	-	262	282	298	-	298	321	339	-	340	366	386	-	382	411	434	-	422	454	480	-											
		LO PR	102	109	119	-	108	115	126	-	112	120	131	-	118	126	137	-	124	132	144	-	128	136	149	-											
		MBh	171.2	177.5	194.5	-	167.3	173.4	189.9	-	163.3	169.2	185.4	-	159.3	165.1	180.9	-	151.3	156.9	171.9	-	140.2	145.3	159.2	-											
70	5400	S/T	0.68	0.57	0.39	-	0.70	0.59	0.41	-	0.72	0.60	0.42	-	0.74	0.62	0.43	-	0.77	0.65	0.45	-	0.78	0.65	0.45	-											
		ΔT	20	17	13	-	20	17	13	-	20	17	13	-	20	17	13	-	20	17	13	-	19	16	12	-											
		HI PR	231	249	263	-	260	279	295	-	295	318	336	-	336	362	382	-	378	407	430	-	418	450	475	-											
		LO PR	101	108	118	-	107	114	124	-	111	118	129	-	117	124	136	-	122	130	142	-	127	135	147	-											
		MBh	158.1	163.8	179.5	-	154.4	160.0	175.3	-	150.7	156.2	171.1	-	147.0	152.4	167.0	-	139.7	144.8	158.6	-	129.4	134.1	146.9	-											
		S/T	0.65	0.55	0.38	-	0.68	0.57	0.39	-	0.70	0.58	0.40	-	0.72	0.60	0.42	-	0.74	0.62	0.43	-	0.75	0.63	0.43	-											
4320	ΔT	22	19	14	-	22	19	15	-	22	19	15	-	22	19	15	-	22	19	15	-	21	18	14	-												
	HI PR	224	242	255	-	252	271	286	-	286	308	326	-	326	351	371	-	367	395	417	-	406	436	461	-												
	LO PR	98	105	114	-	104	110	121	-	108	115	125	-	113	121	132	-	119	126	138	-	123	131	143	-												

75	6075	MBh	179.4	184.7	199.9	214.5	175.2	180.4	195.3	209.6	171.0	176.1	190.6	204.6	166.9	171.8	186.0	199.6	158.5	163.2	176.7	189.6	146.8	151.2	163.6	175.6
		S/T	0.81	0.72	0.55	0.35	0.84	0.75	0.57	0.37	0.86	0.77	0.58	0.37	0.89	0.79	0.60	0.39	0.92	0.82	0.62	0.40	0.93	0.83	0.63	0.40
		ΔT	22	20	17	11	22	20	17	12	22	20	17	12	22	21	17	12	22	20	17	12	21	19	16	11
		Hi PR	236	254	268	280	265	285	301	314	301	324	342	357	343	369	390	407	386	415	439	458	427	459	485	506
		LO PR	103	110	120	128	109	116	127	135	114	121	132	140	119	127	138	147	125	133	145	155	129	138	150	160
	MBh	174.2	179.3	194.1	208.3	170.1	175.1	189.6	203.5	166.1	171.0	185.1	198.6	162.0	166.8	180.5	193.8	153.9	158.5	171.5	184.1	142.6	146.8	158.9	170.5	
	S/T	0.77	0.69	0.52	0.34	0.80	0.71	0.54	0.35	0.82	0.73	0.55	0.36	0.85	0.76	0.57	0.37	0.88	0.79	0.59	0.38	0.89	0.79	0.60	0.39	
	ΔT	23	21	17	12	23	21	17	12	23	21	17	12	23	21	18	12	23	21	17	12	21	20	16	11	
	Hi PR	234	252	266	277	262	282	298	311	298	321	339	354	340	366	386	403	382	411	434	453	422	454	480	501	
	LO PR	102	109	119	127	108	115	126	134	112	120	131	139	118	126	137	146	124	132	144	153	128	136	149	158	
4320	MBh	160.7	165.5	179.1	192.3	157.0	161.6	175.0	187.8	153.3	157.8	170.8	183.3	149.5	154.0	166.6	178.8	142.0	146.3	158.3	169.9	131.6	135.5	146.6	157.4	
	S/T	0.74	0.67	0.50	0.32	0.77	0.69	0.52	0.34	0.79	0.71	0.53	0.34	0.82	0.73	0.55	0.36	0.85	0.76	0.57	0.37	0.85	0.76	0.58	0.37	
	ΔT	25	23	19	13	26	24	19	13	26	24	19	13	26	24	20	14	26	24	19	13	24	22	18	12	
	Hi PR	227	244	258	269	254	274	289	302	289	311	329	343	330	355	375	391	371	399	421	439	410	441	466	486	
	LO PR	99	106	115	123	105	112	122	130	109	116	127	135	115	122	133	142	120	128	139	148	124	132	144	154	

DB: Entering Indoor Dry Bulb Temperature	Shaded area reflects ACCA (TVA) conditions	High and low pressures are measured at the liquid and suction access fittings.
--	--	--

EXPANDED COOLING DATA — 15 TONS (CONT.)

		OUTDOOR AMBIENT TEMPERATURE																							
		65				75				85				95				105				115			
		ENTERING INDOOR WET BULB TEMPERATURE																							
IDB	AIRFLOW	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71				
6075	MBh	182.6	186.5	199.3	213.1	178.3	182.2	194.7	208.1	174.1	177.9	190.0	203.1	169.8	173.5	185.4	198.2	161.3	164.9	176.1	188.3				
	S/T	0.89	0.83	0.68	0.51	0.92	0.86	0.70	0.52	0.94	0.88	0.72	0.54	1.00	0.91	0.74	0.56	1.00	0.95	0.77	0.58				
	ΔT	25	23	20	16	25	24	21	17	25	24	21	17	26	24	21	17	24	24	21	16				
	HI PR	238	257	271	283	268	288	304	317	304	328	346	361	347	373	394	411	390	420	443	462				
	LO PR	104	111	121	129	110	117	128	136	115	122	133	142	120	128	140	149	126	134	147	156				
5400	MBh	177.2	181.1	193.5	206.9	173.1	176.9	189.0	202.0	169.0	172.7	184.5	197.2	164.9	168.5	180.0	192.4	156.6	160.1	171.0	182.8				
	S/T	0.85	0.79	0.65	0.48	0.88	0.82	0.67	0.50	0.90	0.84	0.69	0.51	0.93	0.87	0.71	0.53	0.96	0.90	0.74	0.55				
	ΔT	26	24	21	17	26	25	22	17	26	25	22	17	26	25	22	17	26	25	21	17				
	HI PR	236	254	268	280	265	285	301	314	301	324	342	357	343	369	390	407	386	415	439	458				
	LO PR	103	110	120	128	109	116	127	135	114	121	132	140	119	127	139	148	125	133	145	155				
4320	MBh	163.6	167.2	178.6	190.9	159.8	163.3	174.4	186.5	156.0	159.4	170.3	182.0	152.2	155.5	166.1	177.6	144.6	147.7	157.8	168.7				
	S/T	0.82	0.76	0.62	0.47	0.85	0.79	0.65	0.48	0.87	0.81	0.66	0.49	0.89	0.84	0.68	0.51	0.93	0.87	0.71	0.53				
	ΔT	28	27	24	19	29	28	24	19	29	28	24	19	29	28	24	19	29	27	24	19				
	HI PR	229	246	260	271	257	277	292	305	292	315	332	346	333	358	378	395	375	403	426	444				
	LO PR	100	107	116	124	106	113	123	131	110	117	128	136	116	123	134	143	121	129	141	150				

85	6075	MBh	185.8	189.3	198.3	211.6	181.4	184.9	193.7	206.6	177.1	180.5	189.1	201.7	172.8	176.1	184.5	196.8	164.2	167.3	175.2	187.0
		S/T	0.93	0.90	0.81	0.66	0.96	0.93	0.84	0.68	0.99	0.95	0.86	0.70	1.00	0.98	0.89	0.72	1.00	1.00	0.92	0.75
		ΔT	26	26	24	21	26	26	25	21	26	26	25	21	26	26	25	21	25	25	24	21
		HI PR	241	259	274	285	270	291	307	320	307	331	349	364	350	377	398	415	394	424	448	467
	5400	LO PR	105	112	122	130	111	119	129	138	116	123	135	143	122	129	141	150	127	136	148	158
		MBh	180.3	183.8	192.5	205.4	176.1	179.6	188.1	200.6	172.0	175.3	183.6	195.8	167.8	171.0	179.1	191.1	159.4	162.5	170.1	181.5
		S/T	0.89	0.86	0.77	0.63	0.92	0.89	0.80	0.65	0.94	0.91	0.82	0.67	0.97	0.94	0.85	0.69	1.00	0.97	0.88	0.71
		ΔT	27	27	25	22	28	27	26	22	28	27	26	22	28	27	26	22	27	27	25	22
	4320	HI PR	238	257	271	283	268	288	304	317	304	328	346	361	347	373	394	411	390	420	443	462
		LO PR	104	111	121	129	110	117	128	136	115	122	133	142	120	128	140	149	126	134	147	156
		MBh	166.5	169.7	177.7	189.6	162.6	165.7	173.6	185.2	158.7	161.8	169.4	180.8	154.8	157.8	165.3	176.4	147.1	149.9	157.0	167.5
		S/T	0.86	0.83	0.74	0.60	0.89	0.86	0.77	0.63	0.91	0.88	0.79	0.64	0.94	0.91	0.82	0.66	0.97	0.94	0.85	0.69

IDB: Entering Indoor Dry Bulb Temperature

Shaded area reflects AHRI (TVA) conditions

High and low pressures are measured at the liquid and suction access fittings.

EXPANDED COOLING DATA — 20 TONS

IDB		OUTDOOR AMBIENT TEMPERATURE																																			
		65						75						85						95						105						115					
		ENTERING INDOOR WET BULB TEMPERATURE																																			
AIRFLOW	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71									
7875	MBh	235.2	243.8	267.1	-	229.7	238.1	260.9	-	224.2	232.4	254.6	-	218.8	226.8	248.4	-	207.8	215.4	236.0	-	192.5	199.5	218.6	-												
	S/T	0.71	0.59	0.41	-	0.74	0.62	0.43	-	0.76	0.63	0.44	-	0.78	0.65	0.45	-	0.81	0.68	0.47	-	0.82	0.68	0.47	-												
	ΔT	20	17	13	-	20	17	13	-	20	17	13	-	20	17	13	-	20	17	13	-	18	16	12	-												
	HI PR	268	289	305	-	301	324	342	-	343	369	389	-	390	420	443	-	439	472	499	-	485	522	551	-												
	LO PR	99	105	115	-	105	111	121	-	109	116	126	-	114	121	133	-	120	127	139	-	124	132	144	-												
70	MBh	228.3	236.7	259.3	-	223.0	231.2	253.3	-	217.7	225.7	247.2	-	212.4	220.1	241.2	-	201.8	209.1	229.1	-	186.9	193.7	212.3	-												
	S/T	0.68	0.57	0.39	-	0.70	0.59	0.41	-	0.72	0.60	0.42	-	0.74	0.62	0.43	-	0.77	0.65	0.45	-	0.78	0.65	0.45	-												
	ΔT	20	18	13	-	21	18	14	-	21	18	14	-	21	18	14	-	20	18	13	-	19	17	13	-												
	HI PR	266	286	302	-	298	321	339	-	339	365	385	-	386	416	439	-	435	468	494	-	480	517	546	-												
	LO PR	98	104	114	-	104	110	120	-	108	115	125	-	113	120	131	-	118	126	138	-	123	130	142	-												
5600	MBh	210.7	218.4	239.3	-	205.8	213.4	233.8	-	200.9	208.3	228.2	-	196.0	203.2	222.6	-	186.2	193.0	211.5	-	172.5	178.8	195.9	-												
	S/T	0.65	0.55	0.38	-	0.68	0.57	0.39	-	0.70	0.58	0.40	-	0.72	0.60	0.42	-	0.74	0.62	0.43	-	0.75	0.63	0.43	-												
	ΔT	23	20	15	-	23	20	15	-	23	20	15	-	23	20	15	-	23	20	15	-	21	18	14	-												
	HI PR	258	277	293	-	289	311	329	-	329	354	374	-	375	403	426	-	422	454	479	-	466	501	529	-												
	LO PR	95	101	110	-	100	107	117	-	104	111	121	-	110	117	127	-	115	122	133	-	119	126	138	-												

75	AIRFLOW	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71
	MBh	239.2	246.2	266.5	286.1	233.6	240.5	260.3	279.4	228.0	234.8	254.1	272.8	222.5	229.1	247.9	266.1	211.4	217.6	235.5	252.8	195.8	201.6	218.2	234.2
	S/T	0.81	0.72	0.55	0.35	0.84	0.75	0.57	0.37	0.86	0.77	0.58	0.37	0.89	0.79	0.60	0.39	0.92	0.82	0.62	0.40	0.93	0.83	0.63	0.40
	ΔT	23	21	17	12	23	21	17	12	23	21	17	12	23	21	17	12	23	21	17	12	21	20	16	11
	HI PR	271	292	308	321	304	327	346	361	346	372	393	410	394	424	448	467	443	477	504	526	490	527	557	581
	LO PR	100	106	116	124	106	112	123	131	110	117	128	136	115	123	134	143	121	129	140	150	125	133	145	155
7000	MBh	232.2	239.1	258.8	277.7	226.8	233.5	252.8	271.3	221.4	228.0	246.7	264.8	216.0	222.4	240.7	258.4	205.2	211.3	228.7	245.4	190.1	195.7	211.8	227.4
	S/T	0.77	0.69	0.52	0.34	0.80	0.71	0.54	0.35	0.82	0.73	0.55	0.36	0.85	0.76	0.57	0.37	0.88	0.79	0.59	0.38	0.89	0.79	0.60	0.39
	ΔT	24	22	18	12	24	22	18	12	24	22	18	12	24	22	18	12	24	22	18	12	22	20	17	12
	HI PR	269	289	305	318	301	324	342	357	343	369	389	406	390	420	444	463	439	473	499	520	485	522	551	575
	LO PR	99	105	115	122	105	111	122	129	109	116	126	135	114	122	133	141	120	127	139	148	124	132	144	153
	MBh	214.3	220.7	238.8	256.3	209.3	215.5	233.3	250.4	204.4	210.4	227.7	244.4	199.4	205.3	222.2	238.5	189.4	195.0	211.1	226.5	175.4	180.6	195.5	209.8
5600	S/T	0.74	0.67	0.50	0.32	0.77	0.69	0.52	0.34	0.79	0.71	0.53	0.34	0.82	0.73	0.55	0.36	0.85	0.76	0.57	0.37	0.85	0.76	0.58	0.37
	ΔT	26	24	20	14	26	24	20	14	27	24	20	14	27	25	20	14	26	24	20	14	25	23	19	13
	HI PR	260	280	296	309	292	315	332	346	332	358	378	394	379	407	430	449	426	458	484	505	471	506	535	558
	LO PR	96	102	112	119	101	108	118	126	105	112	123	130	111	118	129	137	116	124	135	144	120	128	139	149

IDB: Entering Indoor Dry Bulb Temperature

Shaded area reflects ACCA (TVA) conditions




High and low pressures are measured at the liquid and suction access fittings.

EXPANDED COOLING DATA — 20 Tons (cont.)

		OUTDOOR AMBIENT TEMPERATURE																								
		65				75				85				95				105				115				
		ENTERING INDOOR WET BULB TEMPERATURE																								
IDB	AIRFLOW	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	
80	7875	MBh	243.4	248.7	265.7	284.1	237.8	242.9	259.6	277.5	232.1	237.2	253.4	270.9	226.4	231.4	247.2	264.3	215.1	219.8	234.8	251.0	199.3	203.6	217.5	232.5
		S/T	0.89	0.83	0.68	0.51	0.92	0.86	0.70	0.52	0.94	0.88	0.72	0.54	1.00	0.91	0.74	0.56	1.00	0.95	0.77	0.58	1.00	0.95	0.78	0.58
		ΔT	25	24	21	17	26	24	21	17	26	24	21	17	26	25	21	17	25	24	21	17	23	23	20	16
		HI PR	274	295	311	325	307	331	349	364	350	376	397	414	398	428	452	472	448	482	509	531	495	533	562	587
	7000	LO PR	101	107	117	125	107	114	124	132	111	118	129	137	117	124	135	144	122	130	142	151	126	134	147	156
		MBh	236.3	241.5	258.0	275.8	230.8	235.9	252.0	269.4	225.3	230.3	246.0	263.0	219.8	224.6	240.0	256.6	208.8	213.4	228.0	243.7	193.5	197.7	211.2	225.8
		S/T	0.85	0.79	0.65	0.48	0.88	0.82	0.67	0.50	0.90	0.84	0.69	0.51	0.93	0.87	0.71	0.53	0.96	0.90	0.74	0.55	0.97	0.91	0.74	0.55
		ΔT	26	25	22	17	27	25	22	18	27	25	22	18	27	26	22	18	26	25	22	18	25	24	21	16
	5600	HI PR	271	292	308	321	304	328	346	361	346	372	393	410	394	424	448	467	444	477	504	526	490	527	557	581
		LO PR	100	106	116	124	106	112	123	131	110	117	128	136	115	123	134	143	121	129	140	150	125	133	145	155
		MBh	218.1	222.9	238.1	254.6	213.1	217.7	232.6	248.6	208.0	212.5	227.1	242.7	202.9	207.3	221.5	236.8	192.8	197.0	210.4	225.0	178.6	182.5	194.9	208.4
		S/T	0.82	0.76	0.62	0.47	0.85	0.79	0.65	0.48	0.87	0.81	0.66	0.49	0.89	0.84	0.68	0.51	0.93	0.87	0.71	0.53	0.94	0.88	0.71	0.53
5600	ΔT	29	28	24	19	30	28	25	20	30	28	25	20	30	29	25	20	29	28	24	20	27	26	23	18	
	HI PR	263	283	299	312	295	318	335	350	336	361	382	398	382	412	435	453	430	463	489	510	475	512	540	563	
	LO PR	97	103	113	120	103	109	119	127	107	113	124	132	112	119	130	138	117	125	136	145	121	129	141	150	


IDB: Entering Indoor Dry Bulb Temperature
 Shaded area reflects AHRI (TVA) conditions
 High and low pressures are measured at the liquid and suction access fittings.

DIMENSIONS




UNIT CLEARANCES

Maintain an adequate clearance around the unit for safety, service, maintenance, and proper unit operation. Leave a total clearance of 75" on the main control panel side of the unit for possible removal of fan shaft, coil, electric heat, and gas furnace. Leave a clearance of 48" on all other sides of the unit for possible compressor removal or service access, and to ensure proper ventilation and condenser airflow. Do not install the unit beneath any obstruction. Install the unit away from all building exhausts to inhibit ingestion of exhaust air into the unit's fresh-air intake.



ELECTRICAL ENTRANCE LOCATIONS



ROOF CURB INSTALLATION — RIGGING

Provisions for forks have been included in the unit base frame. No other fork locations are approved.



- Unit must be lifted by the four lifting holes located at the base frame corners.
- Lifting cables should be attached to the unit with shackles.
- The distance between the crane hook and the top of the unit must not be less than 60”.
- Two spreader bars must span over the unit to prevent damage to the cabinet by the lift cables. Spreader bars must be of sufficient length so that cables do not come in contact with the unit during transport. Remove wood struts mounted beneath unit base frame before setting unit on roof curb. These struts are intended to protect unit base frame from fork lift damage. To remove the struts, extract the sheet metal retainers and pull the struts through the base of the unit. Refer to rigging label on the unit.

Important: If using bottom discharge with roof curb, duct-work should be attached to the curb prior to installing the unit. Duct-work dimensions are shown in Roof Curb Installation Instructions Manual.

Refer to the Roof Curb Installation Instructions for proper curb installation. Curbing must be installed in compliance with the National Roofing Contractors Association Manual.

Lower unit carefully onto roof mounting curb. While rigging the unit, the center of gravity will cause the condenser end to be lower than the supply air end.

Bring condenser end of unit into alignment with the curb. With condenser end of the unit resting on curb member and using curb as a fulcrum, lower opposite end of the unit until entire unit is seated on the curb. When a rectangular cantilever curb is used, take care to center the unit. Check for proper alignment and orientation of supply and return openings with duct.



CORNER & CENTER-OF-GRAVITY LOCATIONS

15-TON UNITS	WEIGHTS (LBS.)
Corner Weight A	570
Corner Weight B	535
Corner Weight C	545
Corner Weight D	510
Shipping Weight	2270
Operating Weight	2155

20-TON UNITS	WEIGHTS (LBS.)
Corner Weight A	655
Corner Weight B	535
Corner Weight C	600
Corner Weight D	485
Shipping Weight	2390
Operating Weight	2275

To assist in determining rigging requirements, unit weights are shown to the right.

Note: These weights are calculated without installed accessories.

ROOF CURB INSTALLATION

Curb installations must comply with local codes and should follow the established guidelines of the National Roofing Contractors Association.


Proper unit installation requires that the roof curb be firmly and permanently attached to the roof structure. Check for adequate fastening method prior to setting the unit on the curb.


Full perimeter roof curbs are available from the factory and are shipped unassembled. The installing contractor is responsible for field assembly, squaring, leveling, and mounting on the roof structure. All required hardware necessary for the assembly of the sheet metal curb is included in the curb accessory package.

- Determine sufficient structural support before locating and mounting the curb and package unit.
- Duct-work must be constructed using industry guidelines. The duct-work must be placed into the roof curb before mounting the package unit. Our full perimeter curbs include duct connection frames to be assembled with the curb. Cantilevered-type curbs are not available from the factory.
- Contractor furnishes curb insulation, cant strips, flashing, and general roofing material.
- Support curbs on parallel sides with roof members. To prevent damage to the unit, the roof members cannot penetrate supply and return duct openings.


Note: The unit and curb accessories are designed to allow vertical duct installation before unit placement. Duct installation after unit placement is not recommended.

See the manual shipped with the roof curb for assembly and installation instructions.





WIRING DIAGRAM — CPG180/240***3B*** THREE-PHASE 208-230 BELT DRIVE




High Voltage: Disconnect all power before servicing or installing this unit. Multiple power sources may be present. Failure to do so may cause property damage, personal injury, or death.



Wiring is subject to change. Always refer to the wiring diagram or the unit for the most up-to-date wiring.

0140L00955 REV A

WIRING DIAGRAM — CPG180/240***4B***/7B* THREE-PHASE 460/575 BELT DRIVE




⚡
High Voltage: Disconnect all power before servicing or installing this unit. Multiple power sources may be present. Failure to do so may cause property damage, personal injury, or death.

WARNING

⚠️

Wiring is subject to change. Always refer to the wiring diagram or the unit for the most up-to-date wiring.

WIRING DIAGRAM — CPG180/240***4B/7B*** THREE-PHASE 460/575 BELT DRIVE



High Voltage: Disconnect all power before servicing or installing this unit. Multiple power sources may be present. Failure to do so may cause property damage, personal injury, or death.



Wiring is subject to change. Always refer to the wiring diagram or the unit for the most up-to-date wiring.

ACCESSORIES

ITEM #	DESCRIPTION	FITS MODEL SIZES
14CURB180240	Roof Curb 14" Tall	15-20 tons
25FD180240	25% Manual Fresh Air Damper	15-20 tons
25MFD180240	25% Motorized Fresh Air Damper	15-20 tons
CDK180	Concentric Duct Kit	15 tons
CDK240	Concentric Duct Kit	20 tons
DNECONGS180240	Downflow Economizer	15-20 tons
GHRC-1	Hurricane Restraint Clip	All Models
HAKT36300	High Altitude Kit	All Models
LPKT180240	LP Conversion Kit	
HSKT180	High Static Kit	15 tons
HSKT240	High Static Kit	20 tons
HZCURB180240ED	Horizontal Discharge Curb — End Discharge	15-20 tons
HZCURB180240SDS	Horizontal Discharge Curb — Side Discharge ¹	15-20 tons
HZCURB180240SDN	Horizontal Discharge Curb — Side Discharge ²	15-20 tons
LAKT03	Low Ambient Kit	15-20 tons
PE1802402	Power Exhaust 208/230v	15-20 tons
PE1802404	Power Exhaust 460v	15-20 tons

¹ Duct openings on service side

² Duct openings on non-service side

